



January 22, 2014

Greene County EDTP
PO Box 996
Tannersville, N.Y. 12485
Att: Michelle Yost

Re: Certified NYS Asbestos survey
For purpose of demolition of the Magnotta Single Family Residence
518 High Falls Extension
Catskill, Greene County, NY
Tax Map # 185.02-2-6
KA # 81513.37.06

Dear Michelle,

The following report is the result of our asbestos survey for the house on the property (mentioned above) required for demolition. As requested, building material samples were taken inside the house and outside from the roof of the house on January 13, 2014 of suspect Asbestos containing material (ACM), as per New York State Industrial Code Rule 56-5.1 Survey Requirements for Building/Structural Demolition, Remodeling and Repair (ICR56) and OSHA Code of Federal Regulations, 40 CFR Ch. 1 (7-1-03 Edition) S763.86, sampling by Michael P. Bliss (see attached NYS Certification Number AH 01-159929). The samples (see attached Bulk Sampling Chain of Custody two pages, dated January 13, 2014 were then delivered to Spectrum Environmental Associates January 14, 2014 for purposes of laboratory analysis (see attached PLM Bulk Asbestos Reports six pages and Summary of Bulk Asbestos Analysis Results three pages for results.

None of the lab results came back positive (contained asbestos with more than 1% asbestos by weight). **A NYS certified asbestos abatement contractor is not required** to remove any material prior to demolition. If during demolition any suspect ACM is observed from within any building cavities that were hidden, the demolition needs to stop immediately and a Certified Asbestos Inspector notified to take additional samples for testing before any further demolition can continue in that area.

Remember to forward this report to the DOL for your demolition permit and also keep a copy of this report at the building during any of the demolition. If you have any questions please call.

Respectfully,
Kaaterskill Associates

Michael P. Bliss, NYS Certified Asbestos Inspector

CC: Darrin Elsom, PE

Encl: Asbestos Inspector Certificate, Inspector Refresher Requirements Certificate, Bulk Sampling Chain of Custody Report, PLM Bulk Asbestos Report, Summary of Bulk Asbestos Analysis Results, Spectrum Environmental Associates Asbestos handling license, and credentials.



Please Reply To:

AmeriSci New York

117 EAST 30TH ST.
NEW YORK, NY 10016
TEL: (212) 679-8600 • FAX: (212) 679-3114

FACSIMILE TELECOPY TRANSMISSION

To: Bill Massman
Spectrum Environmental Associates, Inc.
Fax #:
Email:

From: Aleksandr Barengolts
AmeriSci Job #: 214012290
Subject: ELAP-PLM/TEM 5 day Results
Client Project: 14-015 / 81513.37.06; FEMA Buyout; Masnotta

Date: Monday, January 20, 2014
Time: 19:11:03

Number of Pages: 12
(including cover sheet)

Comments:

CONFIDENTIALITY NOTICE: Unless otherwise indicated, the information contained in this communication is confidential information intended for use of the individual named above. If the reader of this communication is not the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is prohibited. If you have received this communication in error, please immediately notify the sender by telephone and return the original message to the above address via the US Postal Service at our expense. Preliminary data reported here will be verified before final report is issued. Samples are disposed of in 60 days or unless otherwise instructed by the protocol or special instructions in writing. Thank you.

Certified Analysis Service 24 Hours A Day • 7 Days A Week Competitive Prices
visit our web site - www.amerisci.com

Boston • Los Angeles • New York • Richmond



AmeriSci New York

117 EAST 30TH ST.
NEW YORK, NY 10016
TEL: (212) 679-8600 • FAX: (212) 679-3114

PLM Bulk Asbestos Report

Spectrum Environmental Associates, Inc **Date Received** 01/15/14 **AmeriSci Job #** 214012290
 Attn: Bill Massman **Date Examined** 01/20/14 **P.O. #**
 P.O.Box 1024 **ELAP #** 11480 **Page** 1 of 6
RE: 14-015 / 81513.37.06; FEMA Buyout; Masnotta
 Schenectady, NY 12301

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
01 1	214012290-01 Location: Asphalt Roofing - R - Right Side Roof	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Black, Homogeneous, Non-Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Non-fibrous 4.8 %			
02 1	214012290-02 Location: Asphalt Roofing - R - Right Side Roof	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Black, Homogeneous, Non-Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Fibrous glass 3 %, Non-fibrous 60.3 %			
03 2	214012290-03 Location: Roof Cement - Chimney @ Rear	Yes	Trace (<0.25 % pc) ¹ (EPA 400 PC) by Ella Babayeva on 01/20/14
Analyst Description: Black, Homogeneous, Non-Fibrous, Bulk Material			
Asbestos Types: Chrysotile <0.25 % pc			
Other Material: Non-fibrous 2.6 %			
04 2	214012290-04 Location: Roof Cement - Chimney @ Rear	Yes	Trace (<0.25 % pc) ¹ (EPA 400 PC) by Ella Babayeva on 01/20/14
Analyst Description: Black, Homogeneous, Non-Fibrous, Bulk Material			
Asbestos Types: Chrysotile <0.25 % pc			
Other Material: Non-fibrous 2.8 %			
05 3	214012290-05 Location: Caulking - 1st - Window @ Rear (Old Opening)	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Non-fibrous 0.9 %			

Client Name: Spectrum Environmental Associates, Inc.

PLM Bulk Asbestos Report

14-015 / 81513.37.06; FEMA Buyout; Masnotta

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
06 3	214012290-06 Location: Caulking - 1st - Window @ Rear (Old Opening)	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 0.6 %			
07 4	214012290-07 Location: Glazing - Cellar - Window	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Tan, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 33 %			
08 4	214012290-08 Location: Glazing - Cellar - Window	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Tan, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 29 %			
09 5	214012290-09 Location: Chimney Mortar - Cellar - @ Flue Opening	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: Grey, Homogeneous, Non-Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Wollastonite Trace, Non-fibrous 100 %			
10 5	214012290-10 Location: Chimney Mortar - Cellar - @ Flue Opening	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: Grey, Homogeneous, Non-Fibrous, Cementitious, Bulk Material Asbestos Types: Other Material: Wollastonite 5 %, Non-fibrous 95 %			
11 6	214012290-11 Location: Laminate Flooring - 1st - Foyer	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Brown, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 5.6 %			

Client Name: Spectrum Environmental Associates, Inc.

PLM Bulk Asbestos Report

14-015 / 81513.37.06; FEMA Buyout; Masnotta

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
12 6	214012290-12 Location: Laminate Flooring - 1st - Foyer	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Brown, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 8.9 %			
13 7	214012290-13 Location: Mastic - 1st - Foyer	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Tan, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 12.3 %			
14 7	214012290-14 Location: Mastic - 1st - Foyer	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Tan, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 16 %			
15 8	214012290-15 Location: Laminate Flooring - 1st - Kitchen	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Beige, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 11.1 %			
16 8	214012290-16 Location: Laminate Flooring - 1st - Kitchen	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Beige, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 16.3 %			
17 9	214012290-17 Location: Mastic - 1st - Kitchen	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Tan, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 15.1 %			

PLM Bulk Asbestos Report

14-015 / 81513.37.06; FEMA Buyout; Masnotta

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
18 9	214012290-18 Location: Mastic - 1st - Kitchen	No	NAD (by NYS ELAP 198.6) by Ella Babayeva on 01/20/14
Analyst Description: Tan, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 18.2 %			
19 10	214012290-19 Location: Gyp. Bd. - 1st - Walls	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: OffWhite/Tan, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 80 %, Non-fibrous 20 %			
20 10	214012290-20 Location: Gyp. Bd. - 1st - Ceiling	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: OffWhite/Tan, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 85 %, Non-fibrous 15 %			
21 11	214012290-21 Location: Compound - 1st - Walls	No	NAD ² (by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 % Comment: Predominantly Drywall & Paint Submitted			
22 11	214012290-22 Location: Compound - 1st - Walls	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			

PLM Bulk Asbestos Report

14-015 / 81513.37.06; FEMA Buyout; Masnotta

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
23 11	214012290-23 Location: Compound - Loft - Walls	No	NAD ² (by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 % Comment: Predominantly Drywall & Paint Submitted			
24 11	214012290-24 Location: Compound - Loft - Walls	No	NAD ² (by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 % Comment: Predominantly Drywall & Paint Submitted			
25 12	214012290-25 Location: Gyp. Bd. - Loft - Walls	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 % Comment: Material Submitted Appears To Be Joint Compound			
26 12	214012290-26 Location: Gyp. Bd. - Loft - Ceiling	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 % Comment: Material Submitted Appears To Be Joint Compound			
27 13	214012290-27 Location: Compound - Loft - Ceiling	No	NAD (by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: Brown, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 95 %, Non-fibrous 5 % Comment: Material Submitted Appears To Be Drywall			

PLM Bulk Asbestos Report

14-015 / 81513.37.06; FEMA Buyout; Masnotta

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
28	214012290-28	No	NAD
13	Location: Compound - Loft - Ceiling		(by NYS ELAP 198.1) by Ella Babayeva on 01/20/14
Analyst Description: Brown, Homogeneous, Fibrous, Bulk Material			
Asbestos Types:			
Other Material: Cellulose 90 %, Non-fibrous 10 %			
Comment: Material Submitted Appears To Be Drywall			

Reporting Notes:

- (1) Sample prepared for analysis by ELAP 198.6 method
- (2) Insufficient material submitted for accurate quantitation during PLM analysis (no QC possible).

Analyzed by: Ella Babayeva *Ella Babayeva*

*NAD/NSD =no asbestos detected; NA =not analyzed; NA/PS=not analyzed/positive stop; PLM Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP Lab Code 200546-0), ELAP PLM Method 198.1 for NY friable samples, which includes the identification and quantitation of vermiculite or 198.6 for NOB samples or EPA 400 pt ct by EPA 600/M4-82-020 (NY ELAP Lab ID11480); Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile, FR 59,146,38970,8/1/94) National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab.This PLM report relates ONLY to the items tested. AIHA Lab # 102843, RI Cert#AAL-094, CT Cert#PH-0186, Mass Cert#AA000054.

Reviewed By: _____ END OF REPORT _____

Table I
Summary of Bulk Asbestos Analysis Results
 14-015 / 81513.37.06; FEMA Buyout; Masnotta

AmeriSci Sample #	Client Sample#	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
01	01	1	0.189	92.6	2.6	4.8	NAD	NAD
Location: Asphalt Roofing - R - Right Side Roof								
02	02	1	0.420	28.8	7.9	63.3	NAD	NAD
Location: Asphalt Roofing - R - Right Side Roof								
03	03	2	0.078	96.2	1.3	2.5	Chrysotile <0.25	Chrysotile Trace
Location: Roof Cement - Chimney @ Rear								
04	04	2	0.072	94.4	2.8	2.6	Chrysotile <0.25	Chrysotile <1.0
Location: Roof Cement - Chimney @ Rear								
05	05	3	0.106	24.5	74.5	0.9	NAD	NAD
Location: Caulking - 1st - Window @ Rear (Old Opening)								
06	06	3	0.181	27.1	72.4	0.6	NAD	NAD
Location: Caulking - 1st - Window @ Rear (Old Opening)								
07	07	4	0.327	18.0	48.9	33.0	NAD	NAD
Location: Glazing - Cellar - Window								
08	08	4	0.314	16.9	54.1	29.0	NAD	NAD
Location: Glazing - Cellar - Window								
09	09	5	---	---	---	---	NAD	NA
Location: Chimney Mortar - Cellar - @ Flue Opening								
10	10	5	---	---	---	---	NAD	NA
Location: Chimney Mortar - Cellar - @ Flue Opening								
11	11	6	0.198	76.8	17.7	5.6	NAD	NAD
Location: Laminate Flooring - 1st - Foyer								
12	12	6	0.293	76.8	14.3	8.9	NAD	NAD
Location: Laminate Flooring - 1st - Foyer								
13	13	7	0.236	75.0	12.7	12.3	NAD	NAD
Location: Mastic - 1st - Foyer								
14	14	7	0.238	70.2	13.9	16.0	NAD	NAD
Location: Mastic - 1st - Foyer								
15	15	8	0.199	70.4	18.6	11.1	NAD	NAD
Location: Laminate Flooring - 1st - Kitchen								
16	16	8	0.209	70.3	13.4	16.3	NAD	NAD
Location: Laminate Flooring - 1st - Kitchen								

See Reporting notes on last page

Table I
Summary of Bulk Asbestos Analysis Results
 14-015 / 81513.37.06; FEMA Buyout; Masnotta

AmeriSci Sample #	Client Sample#	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
17	17	9	0.139	64.0	20.9	15.1	NAD	NAD
Location: Mastic - 1st - Kitchen								
18	18	9	0.242	65.3	16.5	18.2	NAD	NAD
Location: Mastic - 1st - Kitchen								
19	19	10	---	---	---	---	NAD	NA
Location: Gyp. Bd. - 1st - Walls								
20	20	10	---	---	---	---	NAD	NA
Location: Gyp. Bd. - 1st - Ceiling								
21	21	11	---	---	---	---	NAD	NA
Location: Compound - 1st - Walls								
22	22	11	---	---	---	---	NAD	NA
Location: Compound - 1st - Walls								
23	23	11	---	---	---	---	NAD	NA
Location: Compound - Loft - Walls								
24	24	11	---	---	---	---	NAD	NA
Location: Compound - Loft - Walls								
25	25	12	---	---	---	---	NAD	NA
Location: Gyp. Bd. - Loft - Walls								
26	26	12	---	---	---	---	NAD	NA
Location: Gyp. Bd. - Loft - Ceiling								
27	27	13	---	---	---	---	NAD	NA
Location: Compound - Loft - Ceiling								
28	28	13	---	---	---	---	NAD	NA
Location: Compound - Loft - Ceiling								

Client Name: Spectrum Environmental Associates, Inc.

Table I
Summary of Bulk Asbestos Analysis Results
 14-015 / 81513.37.06; FEMA Buyout; Masnotta


AmeriSci Sample #	Client Sample#	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
-------------------	----------------	---------	----------------------	--------------------------	--------------------------	------------------------------------	-------------------------	----------------------

Analyzed by: Aleksandr Barendolts : Date Analyzed 1/20/2014
 **Quantitative Analysis (Semi/Full); Bulk Asbestos Analysis - PLM by EPA 600/M4-82-020 per 40 CFR or ELAP 198.1 for New York friable samples or ELAP 198.6 for New York NOB samples; TEM (Semi/Full) by EPA 600/R-93/116 (not covered by NVLAP Bulk accreditation) or ELAP 198.4; for New York samples; NAD = no asbestos detected during a quantitative analysis; NA = not analyzed; Trace = <1%; Quantitation for beginning weights of <0.1 grams should be considered as qualitative only; Qualitative Analysis: Asbestos analysis results of "Present" or "NVA = No Visible Asbestos" represents results for Qualitative PLM or TEM Analysis only (no accreditation coverage available from any regulatory agency for qualitative analyses); AIHA Lab # 102843, NVLAP Lab Code 200546-0, NYSDOH ELAP Lab ID#11480.



Warning Note: PLM limitation, only TEM will resolve fibers <0.25 micrometers in diameter. TEM bulk analysis is representative of the fine grained matrix material and may not be representative of non-uniformly dispersed debris for which PLM evaluation is recommended (i.e. soils and other heterogeneous materials).

Reviewed By: _____



SPECTRUM

Environmental Associates, Inc.
 "EXCEEDING OUR CLIENTS EXPECTATIONS OF EXCELLENCE"

P.O. Box 1024
 Schenectady, NY 12301
 (518) 346-6374 (Phone)
 (518) 346-4062 (Fax)
 www.4spectrum.com

214012290

14-015

BULK SAMPLING CHAIN OF CUSTODY

Rev 6-1-08

PROJECT INFORMATION


Project # 81513.37.06	Project Name: FEMA BUYOUT	Matrix	Asbestos Analysis	Lead Analysis	Turnaround
Date Sampled 11/14/14	Building Name: MAGNOTTA	<input checked="" type="checkbox"/> Bulk	<input checked="" type="checkbox"/> PLM - ELAP 198.1	<input type="checkbox"/> AAS - Air	<input type="checkbox"/> RUSH
Page # 1 of 2	Investigator: MIKE BLISS	<input type="checkbox"/> Paint	<input checked="" type="checkbox"/> PLM - ELAP 198.6	<input type="checkbox"/> AAS - Paint	<input type="checkbox"/> 24 Hour
Comments: Unless otherwise stated analyze each group to 1" positive result. ROOF HOMOGENEOUS VINYL SIDING ON WOOD NEW WINDOWS KITCHEN: BATH HOMOGENEOUS FLOORS CARPETING, MASTIC, MOSTLY WOOD PANELING INSIDE TAC STRIPS		<input type="checkbox"/> Soil	<input checked="" type="checkbox"/> TEM - ELAP 198.4	<input type="checkbox"/> AAS - Dust/Wipe	<input type="checkbox"/> 72 Hour
		<input type="checkbox"/> Wipe	<input type="checkbox"/> Other	<input type="checkbox"/> Other	<input checked="" type="checkbox"/> Other 5 days

SAMPLE IDENTIFICATION

Lab ID #	Field ID #	Group #	Material	Floor or Building	Sample Location
01		1	ASPHALT ROOFING	R	RIGHT SIDE ROOF
02		1	"	R	" " "
03		2	ROOF CEMENT	R	CHIMNEY REAR
04		2	"	R	" " "
05		3	CAULKING	1ST	WINDOW REAR (OLD)
06		3	"	"	" " "
07		4	GLAZING	CEILING	WINDOW
08		4	"	"	"
09		5	CHIMNEY MASTIC	"	@ FLUE OPENING
10		5	"	"	"
11		6	LAMINATE FLOORING	1ST	FOTER
12		6	"	"	"
13		7	MASTIC	"	"
14		7	"	"	"
15		8	LAMINATE FLOORING	"	"
16		8	"	"	KITCHEN
17		9	"	"	"
18		9	MASTIC	"	"
19		10	"	"	"
20		10	GYP. BD.	"	WALLS
21		11	"	"	CEILING
22		11	COMPOUND	"	WALLS
23		11	"	"	"
24		11	"	ROFT	WALLS
25		12	GYP BD	"	"
26		12	"	"	CEILING

CHAIN OF CUSTODY

Relinquished By	Date	Time	Received By	Date	Time	Method of Submittal
	11/14/14	2:30		11/14/14	2:30	Drop Off
				11/15/14	1:22	



Spectrum Environmental Associates, Inc.

Exceeding our Clients Expectations of Excellence

This is to certify that

Michael P. Bliss



Social Security #: XXX-XX-5404

Has Successfully Completed The:

Asbestos Building Inspector Refresher Course
Also satisfies the N.Y.S.D.O.H. Building Inspector Refresher Requirements

This course is EPA and New York State Department Of Health approved pursuant to Article 30, Section 905 of the New York State Labor Law as required under Title 10, Chapter 11, Subchapter H, Part 73 NYSCRR.

The DOH 2832 certificate issued is the official record of this training course.

100	4/4/13
Exam Score	Course Date(s)
4/4/2013	
Exam Date	
664225	4/4/2014
DOH 2832	Expiration Date
Certificate Number	
	
	Kathy D. McCollum, Instructor
	
	Kathy D. McCollum Director of Training

2539 Albany Street, Box 1024 - Schenectady, New York 12301 - 1024
Phone: (518) 346-6374 | Fax: (518) 346-4062 | www.Aspectrum.com


RESPIRATOR FIT CERTIFICATION

NAME Michael Bliss
 S.S.# 084 503404 NEXT TEST DUE 4/26/14
 EMPLOYER Yanetski ASSOC
 FULL FACE HALF FACE FULL FACE HALF FACE
 MAKE/MODEL 3M MAKE/MODEL _____ MAKE/MODEL _____
 SIZE Large SIZE _____ SIZE _____
 APPROVAL# _____ APPROVAL# _____ APPROVAL# _____
 FIT FACTOR 100 FIT FACTOR _____ FIT FACTOR _____
Concentra 4/26/13
 TEST OPERATOR DATE ISSUED

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE




MICHAEL P. BLISS
 CLASS (EXPIRES)
 D/INSP (05/14)



CERT# 01-15929
 DMV# 134666477
 MUST BE CARRIED ON ASBESTOS PROJECTS

Occupational Health Centers
 of New York, P.A.
 Affiliated with Concentra

1971 WESTERN AVE.
 ALBANY, NY 12203
 (518) 452-2597
 FAX: (518) 452-4348



EYES GRN
 HAIR BRO
 HGT 6' 04"

IF FOUND RETURN TO:
 NYSOL - L&C UNIT
 ROOM 161A BUILDING 12
 STATE OFFICE CAMPUS
 ALBANY NY 12240

New York State Department of Labor

Division of Safety and Health
License and Certificate Unit
State Campus, Building 12
Albany, NY 12240

ASBESTOS HANDLING LICENSE

Kaaterskill Associates Land Surveying Architecture and
Engineering, P.C.


P.O. Box 1020
Cairo, NY 12413

FILE NUMBER: 00-1040
LICENSE NUMBER: 29739
LICENSE CLASS: RESTRICTED
DATE OF ISSUE: 06/19/2013
EXPIRATION DATE: 06/30/2014

Duly Authorized Representative Michael P. Bliss

This license has been issued in accordance with applicable provisions of Article 30 of the Labor Law of New York State and of the New York State Codes, Rules and Regulations (12 NYCRR Part 56). It is subject to suspension or revocation for a (1) serious violation of state, federal or local laws with regard to the conduct of an asbestos project, or (2) demonstrated lack of responsibility in the conduct of any job involving asbestos or asbestos material.

This license is valid only for the contractor named above and this license or a photocopy must be prominently displayed at the asbestos project worksite. This license verifies that all persons employed by the licensee on an asbestos project in New York State have been issued an Asbestos Certificate, appropriate for the type of work they perform, by the New York State Department of Labor.



Eileen M. Franko, Acting Director
For the Commissioner of Labor